



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/16 Pt.1 T/J(437)

11 July 2016

Delabie Ltd
21/F, On Hing Building,
1 On Hing Terrace,
Central, Hong Kong

(Attn.: Mr Sebastien SPRIET)

Dear Sir,

Approval of "DELABIE" Sensor Flush Valves

Your letters all ref. HK463 dated 29 February 2016, 17 May 2016 and 28 June 2016 refer.

Having considered the test report ref. J19033 issued on 10 May 2016 by Nutek Systems, Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Delabie Ltd.
Country of Origin:	France
Brand:	Delabie
Details of Fitting:	1" Sensor flush valve
Model:	463030HK, 463200HK, 463150HK, 463547
Body Markings:	Delabie
Expiry Date:	15 February 2021

Proviso: As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"Installation of filters before flushing valves is required. Without the filters, the flushing valves are liable to leak. The installed filters need frequent inspection and cleaning to maintain flushing supply. Normally only public toilets with good management system for maintenance would be considered."

"A stop cock or gate valve must be installed at the upstream of the fittings for manual isolation of water supply."

"The design flushing volume of the flushing valves should be compatible with the toilet bowl to ensure that effective clearance can be achieved by a single flush of water."

"Flushing valves should be used within the range of working pressures specified by the manufacturer." AND

"Installation of electronic opening and closing sanitary tapware should also comply with the requirements of Electrical & Mechanical Services Department."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(LAM Ching Man)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/CS(MC)] - with soft copy only